



OPTIMAL REINFORCEMENT PROPOSALS TOWARDS LOSS REDUCTION IN THE DISTRIBUTION NETWORK

A dissertation submitted to the
Department of Electrical Engineering, University of Moratuwa
in partial fulfillment of the requirements for the
degree of Master of Science
Registration No: 07/8425

by
M.M.MOHAMEDSABRY

Supervised by: Prof. H.Y. Ranjit Perera

Department of Electrical Engineering
University of Moratuwa, Sri Lanka

2010

94855



Abstract

Network losses represent a major cost in the delivery of electrical energy. As such they need to be carefully managed. Economic and environmental concerns compel a major focus of attention on any such waste of energy. A clear and accurate policy on loss evaluation and costing is required to ensure that limited capital resources are used to best advantage across the total power system. Distribution loss reduction is in many cases cheaper than commissioning generation plants and fuel for supplying losses over the life of a network. Distribution loss reduction requires a wide range of measures, such as: operations, design, major development projects and network reinforcements.

This study concentrates mainly on proposals for network reinforcements to the Medium voltage distribution system. It is a known fact that about two thirds of feeder losses arise in the first third of main feeder length. Re-conductoring or conversion of such sections can be extremely cost effective.

The objective of this study is to identify and formulate proposals for network reinforcement of the MY distribution system in order to:

- (a) Operate at optimal level of losses
- (b) Provide electricity in sufficient quantity and of acceptable quality
- (c) Ensure efficient electricity distribution based on change of load pattern of the large committed loads and general load growth.

This study has been carried out III the MY distribution network of the Western Province South-I of the Ceylon Electricity Board. SynerGEE computer software has been used to formulate the load flow study. The software model calculates the annual network energy and peak power demand forecast. Required reports and charts generated using the load flow with profile analysis. Load forecast is the primary factor for formulation of network reinforcement proposals. The reinforcement



proposals have been obtained for the years from 2009 to 2013 based on provincial requirement on bottom up approach.

The implementations of network reinforcement proposals incur substantial costs to the utility. With a view to lessen the burden on the utility, the network proposals have been spread throughout the planning period in such a manner that those are implemented exactly as and when necessary. This in turn stagger the investment and helps smooth cash flow. Economic evaluation has been carried out to assess the costs and benefits of the proposed investment. Calculations have been done based on data obtained from the load flow. Results of the economic evaluation of this study are satisfactory. However the performance figures are based on the load forecast and timely implementation of the proposals as scheduled.

Benefits are two folds; quantifiable and unquantifiable. Benefits from improvement of network voltage and supply reliability are difficult to quantify. The readily quantifiable benefit is the reduction of power and energy losses. Only this benefit has been considered for the analysis.

The techniques describes in this study allow a loss reduction strategy to be formulated, based on experience of a typical segment of the network under consideration. For planning purpose, the results of a well chosen pilot scheme can be applied to the entire network; thus allowing the total cost of the scheme and the resulting benefits to be evaluated.

Distribution system loss reduction presents an excellent opportunity for improved energy efficiency. Loss evaluation both difficult and complex. Development of policy and programme require both technical and judgemental analysis. This study summarizes approachesto reduce losses in power distribution systems.

DECLARATION

The work submitted in this dissertation is the result of my own investigation, except where otherwise stated.

It has not already been accepted for any degree, and is also not being concurrently submitted for any other degree.

UOM Verified Signature

M. M. Mohamed Sabry



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations

www.lib.mrt.ac.lk

I endorse the declaration by the candidate.

UOM Verified Signature

Prof. H.Y. Ranjit Perera



CONTENTS

| | Page No. |
|---|-----------|
| Declaration | i |
| Abstract | v |
| Acknowledgement | vii |
| List of Figures | viii |
| List of Tables | ix |
| | |
| 1. Introduction | 1 |
| 1.1 Background | 1 |
| 1.2 Distribution System Losses of the Ceylon Electricity Board | 2 |
| 1.2.1 MV Distribution Network and Losses | 3 |
| 1.2.2 LV Distribution Network and Losses | 4 |
| 1.3 Technical Losses in the Distribution System | 6 |
| 1.4 Technical Loss Reduction Measures | 6 |
| 1.4.1 MV Network Loss Reduction Measures | 8 |
| 1.5 Non-Technical Losses and Reduction Measures | 10 |
| 1.6 Motivation | 10 |
| | |
| 2. Problem statement | 12 |
| 2.1 Identification of the Problem | 12 |
| 2.2 Objectives of the Study | 12 |
| 2.3 Importance of the Study | 13 |
| | |
| 3. Methodology | 14 |
| 3.1 Network Analysis Approach | 14 |
| 3.2 Bottom up Approach | 14 |
| 3.3 Short and Long Term Proposals | 15 |
| 3.4 Technical Loss Reduction Strategy for the MV Distribution Network | 16 |
| 3.5 SynerGEE Electric Computer Software | 17 |
| 3.6 Load Allocation | 18 |
| 3.7 Load Flow Analysis | |
| | |
| 4. Collection of Data and Load Forecast | 28 |
| 4.1 Collection of Data | 28 |
| 4.1.1 Western Province South-I, General Data (Year 2008) | 29 |



| | |
|---|-----------|
| 4.1.2 Western Province South-I, MV Distribution Network (Geographical) | 30 |
| 4.1.3 Present Status of the MV Network | 32 |
| 4.2 Load Forecast | 33 |
| 4.2.1 Regression Analysis | 34 |
| 4.2.2 Forecasted Energy Demand | 35 |
| 4.2.3 Forecasted Peak Power Demand | 36 |
| 4.2.4 Existing Major Loads and Assumed Growth Percentages | 37 |
| 4.2.5 Anticipated Major Loads with Assumed Growth Percentages | 37 |
| 5. MV Network Analysis and Reinforcement Proposals | 39 |
| 5.1 Planning Criteria | 39 |
| 5.2 Analysis | 39 |
| 5.2.1 Charts and Reports | 40 |
| 5.3 Analysis of Year 2010 Network and the Proposed Reinforcements | 41 |
| 5.3.1 Comparison of Technical Losses for the Year 2010 (in kW) | 42 |
| 5.4 Analysis of Year 2011 Network and the Proposed Reinforcements | 43 |
| 5.5 Analysis of Year 2012 Network and the Proposed Reinforcements | 44 |
| 5.6 Analysis of Year 2013 Network and the Proposed Reinforcements | 45 |
| 5.7 Percentage Voltage at Selected Locations with Proposed Reinforcements | 46 |
| 6. Economic Evaluation | 47 |
| 6.1 Power Loss Reduction and Savings | 48 |
| 6.2 Energy Loss Reduction and Savings | 49 |
| 6.3 Overall Scope of Implementation | 51 |
| 6.4 Cost of Implementation | 51 |
| 6.5 Cost for the Implementation (MRs) | 51 |
| 6.6 Total Loss Reduction and Savings (MRs) | 52 |
| 6.7 Calculation of Benefit .Cost Ratio | 52 |
| 6.8 Unquantifiable Benefits | 52 |
| 7. Conclusion and Recommendation | 55 |
| 7.1 Conclusion | 55 |
| 7.2 Recommendation | 56 |

| | |
|---|-----------|
| 7.2.1 Optimization of Distribution System | 56 |
| 7.2.2 Loss Management Policy | 57 |
| 7.2.3 Loss Reduction Programme | 58 |
| 7.3 Further Research Areas | 58 |
| 7.3.1 Network Reinforcements | 58 |
| 7.3.2 Operations | 58 |
| 7.3.3 Design | 59 |
| 7.3.4 Major Projects | 59 |
| References | 60 |



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk



ACKNOWLEDGEMENT

First and foremost, I pay my sincere gratitude to my supervisor Professor Ranjit Perera, Director-General of Public Utilities Commission of Sri Lanka and former Head, Dept. of Electrical Engineering of University of Moratuwa who encouraged and guided me to conduct this investigation and on preparation of the final dissertation.

I would like to take this opportunity to extend my sincere thanks to Mr.U.K.W. Silva, Deputy General Manager (Projects & Heavy Maintenance, Region 4), Dr. H. M. Wijekoon, Chief Engineer (Planning, Region 3) and Mr. L. G. Weerasekara, Chief Engineer (Planning & Development, Region 4) of Ceylon Electricity Board who gave valuable instructions and advice during the study and while preparing the final dissertation.

I would also like to thank my colleagues in the post graduate programme and friends for their support and encouragement.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

It is a great pleasure to remember the kind co-operation extended by my wife and children who helped me to continue the studies from start to end.

ACKNOWLEDGEMENT

First and foremost, I pay my sincere gratitude to my supervisor Professor Ranjit Perera, Director-General of Public Utilities Commission of Sri Lanka and former Head, Dept. of Electrical Engineering of University of Moratuwa who encouraged and guided me to conduct this investigation and on preparation of the final dissertation.

I would like to take this opportunity to extend my sincere thanks to Mr.U.K.W. Silva, Deputy General Manager (Projects & Heavy Maintenance, Region 4), Dr. H. M. Wijekoon, Chief Engineer (Planning, Region 3) and Mr. L. G. Weerasekara, Chief Engineer (Planning & Development, Region 4) of Ceylon Electricity Board who gave valuable instructions and advice during the study and while preparing the final dissertation.

I would also like to thank my colleagues in the post graduate programme and friends for their support and encouragement.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

It is a great pleasure to remember the kind co-operation extended by my wife and children who helped me to continue the studies from start to end.

ACKNOWLEDGEMENT

First and foremost, I pay my sincere gratitude to my supervisor Professor Ranjit Perera, Director-General of Public Utilities Commission of Sri Lanka and former Head, Dept. of Electrical Engineering of University of Moratuwa who encouraged and guided me to conduct this investigation and on preparation of the final dissertation.

I would like to take this opportunity to extend my sincere thanks to Mr.U.K.W. Silva, Deputy General Manager (Projects & Heavy Maintenance, Region 4), Dr. H. M. Wijekoon, Chief Engineer (Planning, Region 3) and Mr. L. G. Weerasekara, Chief Engineer (Planning & Development, Region 4) of Ceylon Electricity Board who gave valuable instructions and advice during the study and while preparing the final dissertation.

I would also like to thank my colleagues in the post graduate programme and friends for their support and encouragement.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

It is a great pleasure to remember the kind co-operation extended by my wife and children who helped me to continue the studies from start to end.

List of Figures

| Figure number | Description |
|------------------|---|
| Figure 1.2 | System Losses (2008) |
| Figure 1.2.1 | Number of Consumers Vs Years |
| Figure 1.2.2 | Percentage Voltage Drop Vs Line length |
| Figure 3.4 | Study Steps at a Glance |
| Figure 3.7 | Load Flow Results |
| Figure 3.7.6 | Sample of Feeder |
| Figure 3.7.10 | Load Flow Diagram |
| Figure 4.2 | Western Province South-I of CEB |
| Figure 4.2.2 (a) | WPS-I MV Distribution Network (Geographical) |
| Figure 4.2.2 (b) | Schematic Diagram of WPS-I |
| Figure 4.4.1 | Past ten year Energy Demand Data -- domestic/commercial |
| Figure 4.4.2 | Past ten year Energy Demand Data -- industrial |
| Figure 4.4.3 | Forecasted Energy Demand |
| Figure 4.4.4 | Forecasted Peak Power demand |
| Figure 5.2.1 | Load Flow Results |
| Figure 5.3 | Year 2010 Network with highlighted locations for reinforcements |
| Figure 5.4 | Year 2011 Network with highlighted locations for reinforcements |
| Figure 5.5 | Year 2012 Network with highlighted locations for reinforcements |
| Figure 5.6 | Year 2013 Network with highlighted locations for reinforcements |
| Figure 5.7 | Voltage % at Selected Locations with Proposals |
| Figure 6.1 (a) | Power Demand Vs Years |
| Figure 6.1(b) | Power Loss Vs Years |
| Figure 6.1 (c) | Power Loss % Vs Years |
| Figure 6.2 (a) | Energy Demand Vs Years |
| Figure 6.2(b) | Energy Loss Vs Years |
| Figure 6.2 (c) | Energy Loss % Vs Years |
| Figure 6.8 (a) | Power Demand Projections |
| Figure 6.8 (b) | Power Demand and Grid Capacity |

List of Tables

| Table number | Description |
|-----------------|--|
| Table 1.1 | Transmission and Distribution Loss % in Selected Countries |
| Table 1.2 | System Losses of CEB (Year 2008) |
| Table 3.7 | Results of a section after load flow study |
| Table 4.1.1 | MV & LV Distribution Network Details of WPS - 1 |
| Table 4.1.2 (a) | WPS - 1 Grid Substations and their Capacities |
| Table 4.1.2 (b) | Existing System's Power Demand and Energy Sales Figures |
| Table 4.1.3 | MV Voltage Drops at Different Locations |
| Table 4.2.1(a) | Past ten year Energy demand data – Domestic/Commercial Sectors |
| Table 4.2.1(b) | Past ten year Energy demand data – Industrial Sector |
| Table 4.2.2 | Forecasted Energy Demand |
| Table 4.2.3 | Forecasted Peak Power Demand |
| Table 4.2.4 | Existing Major Loads |
| Table 4.2.5 | Anticipated Major Loads with assumed growth rates |
| Table 5.3 | Problems and Proposals for year 2010 |
| Table 5.3.1 | Comparison of Technical Losses for the year 2010 |
| Table 5.4 | Problems and Proposals for year 2011 |
| Table 5.5 | Problems and Proposals for year 2012 |
| Table 5.6 | Problems and Proposals for year 2013 |
| Table 5.7 | Percentage Voltage at Selected Locations |
| Table 6.1 | Power Loss Reduction and Savings |
| Table 6.2 | Energy Loss Reduction and Savings |
| Table 6.3 | Overall Scope of Implementation |
| Table 6.5 | Cost for the Implementation (MRs) |
| Table 6.6 | Total Loss Reduction and Savings |
| Table 6.8 | Power Demand and Grid Capacity |

