LE/DON/98/07

DESIGNING AND IMPLIMENTATION OF AN IMPROVED REMOTE SUPERVISORY CONTROL AND VOLTAGE REGULATION SYSTEM AT WIMALASURENDRA POWER STATION

A dissertation submitted to the Department of Electrical Engineering, University of Moratuwa In partial fulfillment of the requirements for the Degree of Master of Science

By

S.W. KUMARAWADU

LIBRARY UNIVERSITY OF MORATUWA, SRI LANKA MORATUWA

Supervised by Dr. Trishantha Nanayakkara

89422

Department of Electrical Engineering

621.3 06 621.3 (043)

89422

University of Moratuwa



December 2006

89422

DECLARATION

I certify that this dissertation does not incorporate without acknowledgement any material previously submitted for a degree or diploma in any University to the best of my knowledge and believe it does not contain any material previously published, written or orally communicated by another person or myself except where due reference is made in the text. I also hereby give consent for my dissertation if accepted, to be made available for photocopying and for interlibrary loans, and for the title and summary tobe made available to outside organizations.

100

S.W. Kumarawadu

Date: 28/01 2007

We/I endorse the declaration by the candidate.

UOM Verified Signature

Dr. D.P. Trishantha Nanayakkara Supervisor

Date: 30/01/2007



CONTENTS

| DECLA | ARATIO | N | | ii |
|----------|----------------|---|---|------|
| CONTENTS | | | | 111 |
| ABSTR | RACT | | | v |
| ACKN | OWLED | GEMENT | | vi |
| LIST C | F FIGUR | RES | | vii |
| LIST C | F TABL | ES | | viii |
| | | | | |
| CHAP | rer - 1 | | | |
| 1 | Introdu | ction | | 01 |
| | 1.1 | Backgro | ound and motivation | 02 |
| | | 1.1.1. W | /imalasurendra power station (WPS) | 02 |
| | | 1.1.2. Pi | resent status of WPS | 03 |
| | 1.2 | Excitation | on system of WPS | 03 |
| | 1.3 | Governi | ng system of WPS | 04 |
| | 1.4 | Evolutio | on of supervisory and control technologies | 05 |
| | 1.5 | Scope o | f work | 06 |
| CHAP | rer - 2 | | | |
| 2 | Designi | Designing and implementation of Remote Supervisory & Control System | | |
| | 2.1 | Remote | Terminal Unit (RTU) | 07 |
| | | 2.1.1 | ADAM-4000 series | 07 |
| | | 2.1.1.1 | Remotely Programmable Input Ranges | 07 |
| | | 2.1.1.2 | Watchdog Timer | 07 |
| | | 2.1.1.3 | Ready for the Industrial Environment | 08 |
| | | 2.1.1.4 | Communication | 08 |
| | | 2.1.1.5 | RS-485 protocol | 08 |
| | | 2.1.2 | Analog Signal Inputs (4-20mA current loops) | 08 |
| | | 2.1.3. | Drawing Survey | 09 |
| | | 2.1.3.1 | Digital (Status) Inputs | 09 |
| | | 2.1.3.2. | Digital Relay Outputs (Control Commands) | 09 |
| | | 2.1.3.3 | Drawings of the Modified Circuits | 10 |
| | | 2.1.4 | Relay Circuits for interfacing old system | 10 |
| | | 2.1.5 | Digital Input Module (ADAM-4051) | 15 |
| | | 2.2.6 | Analog Input Module (ADAM-4017) | 16 |
| | | 2.1.7 | Digital Output Module (ADAM-4068) | 16 |
| | 2.2. | Control | Station | 18 |
| | | 2.2.1. | Converter module (ADAM-4520) | 18 |
| | | 2.2.1.1 | Built-in Intelligence | 18 |

PAGE

.

iii

| | | 2.2.1.2 | RS-485 network with Automatic Data Flow Control | 18 |
|-------|---------|----------------------|---|----|
| | | 2.2.1.3 | Features of ADAM-4520 | 18 |
| | | 2.2.2 | HMI (Human Machine Interface) | 19 |
| | 2.3. | Basic C | onfiguration | 21 |
| | | | | |
| СНАРТ | ER - 3 | | | |
| 3 | Improv | ing the vo | oltage regulation system of WPS | 22 |
| | using n | ew superv | visory & control system. | |
| | 3.1 | Back-gr | ound | 22 |
| | 3.2. | Voltage | Regulation | 22 |
| | | 3.2.1 | Duties of the automatic voltage regulator | 22 |
| | | 3.2.2 | Operational behaviour of synchronous machines | 24 |
| | | 3.2.3 | The principle of cross-current compensation | 26 |
| | | 3.2.4 | Special sequences in undisturbed operation | 27 |
| | | 3.2.5 | The transient behaviour generator – network | 28 |
| | | 3.2.6 | Excitation systems for synchronous machines | 28 |
| | 3.3. | Existing | g voltage regulating system in WPS | 29 |
| | | 3.3.1 | BJ-30 regulator | 29 |
| | | 3.3.2 | Operation principle of existing system | 30 |
| | | 3.3.3 | Present condition | 32 |
| | 3.4. | Testing | of the existing system, for the new design | 32 |
| | | 3.4.1 | Voltage variation During a normal operation | 32 |
| | | 3.4.2 | Behaviour of the voltage variation during | |
| | | | a system instability ac. k | 33 |
| | | 3.4.3 | Analysis for voltage feed back, generator current sensing | 34 |
| | | | and field current Sensing | |
| | | 3.4.3.1 | Analysis of Gen. Voltage feedback | 34 |
| | | 3.4.3.2 | Generator current sensing | 36 |
| | | 3.4.4. | Voltage variation for normal & quick response contacts | 38 |
| | | | QR and QL | |
| | 3.5. | Modific | cation of the excitation system for the design of new AVR | 39 |
| | | 3.5.1 | Description of the Circuit (AVR CCT 1) | 39 |
| | 3.6. | PLC base | ed new voltage regulation system | 41 |
| | | 3.6.1 | Vision 230 PLC unit | 41 |
| | | 3.6.2. | Description of the AVR CCT 2 | 42 |
| | | 3.6.3. | Ladder programming and limit calculations for | 44 |
| | | | voltage feed-back control | |
| | 3.7 | Performance analysis | | 45 |
| | | 3.7.1. | Voltage variation during a normal operation | 45 |
| | | 3.7.2. | Voltage variation during a load rejection | 45 |

ACKNOWLEDGEMENT

First of all, I would like to thank Dr. D.P. Thrishantha Nanayakkara, who guided me through the entire project as the supervisor, with my appreciation and profound indebtedness for his help and advice.

Also I particularly want to thank Prof. Ranjith Perera and Dr. Sisil Kumarawadu for their guidance for the completion of the project.

I extend my sincere thank to Mr. C.P.W. Akarawita, DGM (L/C), CEB, for granting approval to purchase necessary equipment and implement the project at Wimalasurendra Power Station, Mr. S.S.B. Karuanaratne, CE(I & C) and Mr. W.M.T. Wijayananda, EE(I & C) of Laxapana complex for helping me during the project design and implementation and Mr. Vass Gunawardana, ES(m) and the maintenance staff of WPS, for helping me numerous ways.

Further, I would like to extend my sincere thank to My wife Dinusha, daughter Malmudu, loving mother and mother in-law for bearing my absence which they felt badly during the busy period I had while working on this project.

LIST OF FIGURES

| Figure | Description | Page |
|--------------------|--|------|
| Fig. 1-1. | Wimalasurendra Power Station | 02 |
| Fig. 1-2 | Excitation System of WPS | 04 |
| Fig. 1-3 | The evolution of supervisory and control technologies | 05 |
| Fig. 2-1. | Basic Configuration of Analog Circuits | 08 |
| Fig. 2-2. | 12VDC intermediate Auxiliary relays | 10 |
| Fig. 2-3. | 48VDC relays used for control commands | 10 |
| Fig. 2-4. | Status inputs | 11 |
| Fig. 2 - 5. | Control commands | 12 |
| Fig. 2-6. | Excitation control | 13 |
| Fig. 2 - 7. | Governor control | 14 |
| Fig. 2-8 | Digital input, digital output and analog input modules with | 17 |
| E I | temporary connections | |
| Fig. 2-9 | Control station with ADAM4520 converter module, power | 19 |
| W | supply and the visual interface | |
| Fig. 2-10 | Old panel base HMI | 20 |
| Fig. 2-11 | New HMI at remote PC | 20 |
| Fig. 2-12. | Basic Configuration | 21 |
| Fig. 3-1. | Network structure and substitution diagram | 23 |
| Fig. 3-2. | Analogy between governor speed control and AVR voltage control | 25 |
| Fig. 3-3. | Principle of current compensation | 27 |
| Fig. 3.4. | BJ30 Regulator | 29 |
| Fig. 3-5. | Contactor panel | 30 |
| Fig. 3-6. | Schematic wiring diagram of DC exciter generator excitation | 31 |
| | System with type BJ 30 generator voltage regulator | |
| Fig. 3-7. | Generator voltage waveform with manual excitation control during | 32 |
| | normal operation | |
| Fig. 3-8. | Voltage waveform during the load rejection of 3.1MW, 3MVAr | 33 |
| Fig. 3-9. | Graph_Voltage of feed-back analysis | 34 |
| Fig. 3-10. | Graph_Voltage of feed-back analysis | 35 |
| Fig. 3-11. | Graph_Voltage of feed-back analysis | 36 |
| Fig. 3-12. | Graph_Gen. current feed-back analysis | 37 |
| Fig. 3-13. | Graph_ Field current feed-back analysis | 38 |
| Fig. 3-14 | Voltage variation for quick response contacts QR and QL | 38 |

| Fig. 3-15 | Schematic wiring diagram of the excitation system | 39 |
|------------|---|------|
| | with new voltage regulating system | |
| Fig. 3-16. | Gen. T/F combination in parallel operation | 40 |
| Fig. 3-17 | PLC based new circuit (AVR CCT 2) | * 42 |
| Fig. 3-18. | Temporary connected AVR circuitry | 43 |
| Fig. 3-19 | Integer of transducer for voltage Vs Actual voltage | 44 |
| Fig. 3-20 | Voltage variation during a normal operation | 45 |
| Fig. 3-21. | Active and reactive power at load rejection | 46 |
| Fig. 3-22. | Voltage prior to and after the load rejection status II | 46 |
| Fig. 3-23. | Voltage prior to and after the load rejection status III | 47 |
| Fig. 4-2. | Schematic diagram of the AVR with PID controller to prevent | 49 |
| | Relay hunting | |

LIST OF TABLES

| Table | Description | Page |
|------------|--|-------------------|
| Table 2-1. | Digital Status inputsversity of Moratuwa, Sri | |
| Table 2-2. | Digital relay outputs Theses & Disserta | 09 ⁰¹⁵ |
| Table 2-3. | Digital input channels | 15 |
| Table 2-4. | Analog input channels | 16 |
| Table 2-5. | Digital o/p channels | 17 |
| Table 3-1. | Feed backs Vs Output voltage | 34 |
| Table 3-2 | Vol across the fb coil Vs R_{mu} (resistive element) | 35 |
| Table 3-3. | Current feed back | 37 |
| Table 3-4. | Field current feed back | 37 |